



INSTALLATION NOTES:  
 (1) MOUNT APS AT A POINT IN WHICH WATER WILL NOT COLLECT WITHIN THE FIRE PROTECTION PIPING. WE RECOMMEND TO PLACE THE APS AS FAR FROM THE PUMP ROOM AS POSSIBLE.  
 (2) IN WATER SENSITIVE AREAS, USING THE OUTPUT ADAPTER PORT YOU CAN PLUMB THE APS TO A DRAIN VIA (PART # A03-WDK)"N2-BLAST - APS WATER DRAIN ADAPTER KIT".

DRAWING	ECR	REV.	DESCRIPTION	DATE	CHANGED BY	APPROVED BY
-	-	2	ADDED VERTICAL PIPE INSTALLATION INSTRUCTIONS	7/30/2015	PJS	JVN
-	-	1	INSERTED NEW TITLE BLOCK AND CHANGED FONT FORMAT	7/17/2015	PJS	JVN
REVISIONS						



MATERIAL:	<b>APS TYPICAL INSTALLATION</b>		DRAWN:	APPROVED:			
FINISH:			PJS	JVN			
WEIGHT:			DATE:	DATE:			
PROJECT NAME:	AUTOPURGE	SIZE:	B	SCALE:	NTS	SHEET:	1 OF 1
NUMBER:	<b>A03-APS-TI</b>		REVISION:	2			